

10/25/2024
5:34:01 PM

Palm Beach County Fleet Management Asset Maintenance History
10139563 2002 COLEMAN 25KW Generator, 25 Kw, Trailer

Total Hours: 403.20 Labor: 22,574.50 Parts: 3,169.33 Comm: 2,429.94 Charged: 28173.77

Work Order: 241092 **Meter:** 0 **In Date:** 05/29/2002 **Closed:** 05/29/2002
Problem: PRE-DELIVERY INSPECTION

Work Completed

- Pre-delivery Inspection

Hours: 5.00 Comm: 0.00 Labor: 250.00 Parts: 0.00 Total: 250.00

Work Order: 246806 **Meter:** 1 **In Date:** 08/27/2002 **Closed:** 09/26/2002
Problem: CHECK GENERATOR

Work Completed

- Check Generator

Hours: 1.50 Comm: 0.00 Labor: 75.00 Parts: 0.00 Total: 75.00

Work Order: 248982 **Meter:** 1 **In Date:** 10/01/2002 **Closed:** 11/07/2002
Problem: CHECK GENERATOR

Work Completed

- Check Generator 10/7-10/14-10/21-10/28

Hours: 2.00 Comm: 0.00 Labor: 100.00 Parts: 0.00 Total: 100.00

Work Order: 251165 **Meter:** 10 **In Date:** 11/05/2002 **Closed:** 12/20/2002
Problem: CHECK GENERATOR

Work Completed

- Check Generator 12/9-12/17

- Replace Battery

Parts Issued

Quantity

24-60 Battery Group 24 1.00

24-60 Battery Group 24 -1.00

24cf-50 Battery 1.00

Hours: 3.50 Comm: 0.00 Labor: 175.00 Parts: 138.52 Total: 313.52

Work Order: 253572 **Meter:** 10 **In Date:** 12/19/2002 **Closed:** 12/31/2002
Problem: CHECK GENERATOR

Work Completed

- 12/16-12/23-12/30 Weekly Generator Ck

Hours: 1.50 Comm: 0.00 Labor: 75.00 Parts: 0.00 Total: 75.00

10/25/2024
5:34:02 PM

Palm Beach County Fleet Management Asset Maintenance History
10139563 2002 COLEMAN 25KW Generator, 25 Kw, Trailer

Work Order: 932690 **Meter:** 722 **In Date:** 01/12/2009 **Closed:** 02/04/2009
Problem: PM SERVICE, TEST RUN WEEKLY

Work Completed

Parts Issued

Quantity

- Pm Generator	58856 Seal	2.00
- Service Trailer Single Axle	R25p Fuel Filter (frm Ps11026 Wix 33968)	1.00
- Replace Cracked Fuel Line From Seperator To Pump	Air Filter	1.00
- Test Run Weekly	Oil Filter	1.00
	Fuel Filter	1.00
	15/40 Oil	12.00
	Grease Cap Plug	2.00
Hours: 9.00	Comm: 0.00	Labor: 540.00 Parts: 112.07 Total: 652.07

Work Order: 933354 **Meter:** 722 **In Date:** 02/02/2009 **Closed:** 02/27/2009
Problem: TEST RUN WEEKLY

Work Completed

- Test Run Assembly 2/6, 2/13, 2/20, 2/27

Hours: 2.00 Comm: 0.00 Labor: 120.00 Parts: 0.00 Total: 120.00

Work Order: 934843 **Meter:** 722 **In Date:** 03/06/2009 **Closed:** 03/30/2009
Problem: TEST RUN

Work Completed

- 3/6,3/13,3/20,3/27-test Run Weekly

Hours: 2.00 Comm: 0.00 Labor: 120.00 Parts: 0.00 Total: 120.00

Work Order: 935492 **Meter:** 0 **In Date:** 01/29/2009 **Closed:** 03/24/2009
Problem: MURPHYS PAINT & BODY SHOP

Work Completed

- Murphys Paint & Body Shop

Hours: 0.00 Comm: 2,422.80 Labor: 0.00 Parts: 0.00 Total: 2,422.80

10/25/2024
5:34:02 PM

Palm Beach County Fleet Management Asset Maintenance History
10139563 2002 COLEMAN 25KW Generator, 25 Kw, Trailer

Work Order: 1306351 **Meter:** 319 **In Date:** 06/25/2013 **Closed:** 06/27/2013

Problem: pm service/ handle/ see notes

Work Completed

- Pm Service
- Service Trailer
- Replace Rear Jack
- Replace Male Trailer Plug
- Charge Battery And Check Charging Sys
- Shop Supplies

Parts Issued

Quantity

Jack Assy	1.00
Napagold Oil Filter	1.00
15-40 Oil	12.00
Napagold Fuel Filter	1.00
Brake Cleaner	1.00
Trailer Conn Plug	1.00
Shop Supplies	1.00

Hours: 9.00

Comm: 0.00

Labor: 540.00 Parts: 167.06 Total: 707.06

Work Order: 1402549 **Meter:** 322 **In Date:** 03/17/2014 **Closed:** 03/19/2014

Problem: pm service

Work Completed

- Pm
- Service Trailer
- Shop Supplies

Parts Issued

Quantity

Napagold Oil Filter	1.00
Napagold Fuel Filter	1.00
Napa Qt 15w40	12.00
12v5amp/hour Battery	1.00
Pm-22-a Additive Dies	1.00
Wd40 16oz	1.00
Shop Supplies	1.00

Hours: 6.00

Comm: 0.00

Labor: 360.00 Parts: 98.33 Total: 458.33

Work Order: 1402628 **Meter:** 321 **In Date:** 03/18/2014 **Closed:** 03/28/2014

Problem: fuel swap

Work Completed

- Fuel swap
- To Vista lot
- Shop Supplies

Parts Issued

Quantity

Kathon Preservative D	2.00
2401 Diesel Fuel Cond	1.00
Shop Supplies	1.00

Hours: 2.00

Comm: 0.00

Labor: 120.00 Parts: 28.24 Total: 148.24

10/25/2024
5:34:02 PM

Palm Beach County Fleet Management Asset Maintenance History
10139563 2002 COLEMAN 25KW Generator, 25 Kw, Trailer

Work Order: 1510130 **Meter:** 332 **In Date:** 10/06/2015 **Closed:** 10/21/2015
Problem: pm service, back jack handle broken

Work Completed

- Pm
- Service Trailer
- Replace broken Jack on Rear
- Shop Supplies

Parts Issued

Quantity

Napa Qt 15w40	12.00
Napagold Oil Filter	1.00
Napagold Fuel Filter	1.00
Napagold Air Filter	1.00
Napagold Fuel Filter	1.00
Jack Assy	1.00
Shop Supplies	1.00

Hours: 6.50

Comm: 0.00

Labor: 390.00 Parts: 203.39 Total: 593.39

Work Order: 1610686 **Meter:** 332 **In Date:** 10/17/2016 **Closed:** 10/28/2016
Problem: pm/ stalls 3 times then starts

Work Completed

- Pm
- Service Trailer
- R/r all fuel lines an clamps
- R/r breakaway battery sys
- R/r Both tail lamps
- Remove old fuel, take to fuel island, fill and run for 1/2 hour
- Shop Supplies

Parts Issued

Quantity

15-40 Oil	12.00
Napagold Oil Filter	1.00
Napagold Fuel Filter	1.00
Napagold Fuel Filter	1.00
Napagold Air Filter	1.00
Tran Flu Qt Dexron3i	2.00
Seal 1.719 2.561 .500	2.00
Grease Cap	2.00
Fuel Line Hose	8.00
Hose Clamp	8.00
Break Away System	1.00
Led Chmsl Lamp	2.00
Led Adapter Plug	2.00
Shop Supplies	1.00

Hours: 11.00

Comm: 0.00

Labor: 660.00 Parts: 304.13 Total: 964.13

10/25/2024
5:34:02 PM

Palm Beach County Fleet Management Asset Maintenance History
10139563 2002 COLEMAN 25KW Generator, 25 Kw, Trailer

Work Order: 1710656 **Meter:** 348 **In Date:** 10/27/2017 **Closed:** 11/07/2017
Problem: pm service, shuts off after 5 seconds, shows codes

Work Completed

Parts Issued

Quantity

- Pm	Napagold Oil Filter	1.00
- Trailer Service	Napagold Fuel Filter	1.00
- Replace trailer plug	Napagold Fuel Filter	1.00
- Ck for shutting down,-traced to poor connection form alternator to control panel -cleaned wire terminals and test run	15-40 Oil	12.00
- Shop Supplies	Seal 1.719 2.561 .500	2.00
	Male Trailer Connector	1.00
	Shop Supplies	1.00
	Labor: 510.00	Parts: 72.77
		Total: 582.77

Hours: 8.50

Comm: 0.00

Work Order: 1908404 **Meter:** 348 **In Date:** 08/13/2019 **Closed:** 08/28/2019
Problem: pm/ shuts down after 1 minute, overspeed sensor

Work Completed

Parts Issued

Quantity

- Pm Cancelled; customer maintaining	Shop Supplies	1.00
- Check for overspeed shutdown code		
- Shop Supplies		
	Labor: 67.00	Parts: 3.00
		Total: 70.00

Hours: 1.00

Comm: 0.00

Work Order: 2108316 **Meter:** 362 **In Date:** 08/02/2021 **Closed:** 08/31/2021
Problem: Generator will not start. Staff will bring in for review.

Work Completed

Parts Issued

Quantity

- Check over generator. Control panel problems	Shop Supplies	1.00
- Shop Supplies		
	Labor: 73.00	Parts: 2.65
		Total: 75.65

Hours: 1.00

Comm: 0.00

Total Hours: 403.20

Total Labor: 22,574.50

Total Comm: 2,429.94

Total Parts: 3,169.33