



Fire Hydrant Final Request



A request must be submitted for a Fire Hydrant Final for newly installed hydrants. There is no separate fee for hydrant final inspections; this is covered by the civil review fee.

To be added to the schedule, have the Engineer of Record (EOR) email Brett Carlton (BGCarlton@pbc.gov) requesting the inspection with the following information:

- BacT's
- Pressure test results
- Health Department release of construction water letter

Please have the following ready on the day of your inspection, prior to the Inspector's arrival:

- Copy of civil plans that bear the Palm Beach County Fire Rescue Stamp.
- Installation contractor on-site to operate hydrants and valves. They will need to have a gate key and will need to know the locations of all valves.
- Verify all valve boxes are clean and accessible.
- First lift of asphalt and curbs are installed.
- Fire hydrant(s) installed as indicated on plans.
- Temporary construction meters must be removed by the water utility department prior to hydrant testing. If captivator caps are required, they must be installed for the inspection.
- Hydrant is required to be accessible as this is a final and the fire hydrant will be deemed ready for use upon successful inspection.
- If this hydrant was installed as a requirement for a new structure, the general contractor will need to be on-site with plans at time of this inspection.